



PSB Singapore

# CERTIFICATE OF CONFORMITY

Product Listing Scheme\* : **Class 2**

This Certificate is issued to

Kaimann Asia Pacific Pte Ltd  
 150 Cecil Street, #15-01  
 Singapore 069543

## FOR

Product: Thermal Insulation Material

Brand: Kaiflex ST

Model: Kaiflex ST

Country of Origin: Germany

Product Details: Thickness: 6 – 50mm, Density: 50 - 70kg/m<sup>3</sup>  
 Tested with the elastomeric nitrile rubber insulation face exposed to heat.  
 Bonded to 1 – 1.5mm thick steel substrate.

which has complied with the requirements of the scheme and based on the following:

### Standard(s)

British Standard 476 Part 6 : 1989  
 British Standard 476 Part 7 : 1997

### Test Report(s)

TÜV SÜD PSB no. S08MEC03104/OKH,  
 S08MEC01259/B/OKH, 54S073509/A/OKH,  
 54S073509/B/OKH, 54S073509/C/OKH,  
 S08MEC03178/2A/OKH, S08MEC03178/1A/OKH,  
 S08MEC03178/2B/OKH & S08MEC03178/1B/OKH  
 WF no. 158674, 158675 & 158676  
 (Rating : Class '0')

Vice-President (Certification Department)  
 TÜV SÜD PSB

Certificate No:	Date of Original Issue:	Date of Last Revision:	Date of Expiry:
011933	09/06/2008	15/04/2009	30/06/2011



\* All products listed under Class 1A/1B must have this mark affixed / printed on them.  
 Failure to comply with this requirement may result in revocation of this certificate.



This Certificate is part of a full report and should be read in conjunction with it. This Certificate remains the property of TÜV SÜD PSB Pte Ltd and shall be returned upon request. The use of this Certificate is subjected to the terms and conditions of the Product Listing Scheme. The manufacturer is solely responsible for compliance of any product that has the same designation as the product type-tested. Persons relying on this Certificate should verify its validity by checking TÜV SÜD PSB's website at [www.tuv-sud-psb.com](http://www.tuv-sud-psb.com).